

Analytical Results



Five Star Home Inspection

PO Box 2458
Cornelius, NC 28031

Receive Date: 04/28/2020
Reported: 04/30/2020
For: 9780 Unity Church Rd Mooresville NC
Comments: Acceptable limits for drinking water are:

Total Coliform = Absent, E.Coli = Absent, Lead <0.015 mg/L,
Nitrate <10.0 mg/L, Nitrite <1.0 mg/L

Sample Number	Parameter	Sample ID	Result	Unit	Method	Analyzed	Analyst
200428-28-01	E. Coli	Layne	Absent		9223B	04/28/2020	WC
200428-28-01	Lead	Layne	<0.002	mg/L	SM3113B-2004	04/30/2020	MD
200428-28-01	Nitrate	Layne	<1	mg/L	353.2	04/29/2020	CL
200428-28-01	Nitrite	Layne	<0.1	mg/L	353.2	04/29/2020	CL
200428-28-01	Total Coliforms	Layne	Present		9223B	04/28/2020	WC

Respectfully submitted,



Dena Myers
NC Cert #440,
NCDW Cert #37755,
EPA #NC00909